 <b>MAHARASHTRA NATURAL GAS LIMITED</b>	<b>REPLY TO BIDDERS QUERIES AGAINST TENDER FOR RATE CONTRACT FOR THE PERIOD OF 2 YEARS FOR RESTORATION OF ROADS FOR CGD NETWORK OF MNGL, PUNE</b> <b>Bid No.: MNGL/C&amp;P/2017-18/50</b>
---	--

Date: 15.09.2017

**Replies to Queries of the Bidders**

**SUB: Replies to queries of the bidders for Tender for Rate contract for the period of 2 years for restoration of roads under jurisdiction of Corporations, Defence, PWD, Grampanchayat, JNNURM, Irrigation, Railways, National Highways, or any other private / Government Authority in various areas of PMC, PCMC & adjoining areas of Chakan, Talegaon & Hinjewadi for City Gas Distribution Network of MNGL, Pune**

REF: Bid Document No. MNGL/C&P/2017-18/50 dated 16.08.2017, Addendum-I dated 30.08.2017 & Addendum-II dated 08.09.2017.

Dear Sir,

Following are the replies to queries of the bidders. Kindly note the same.


Sl. No.	Bidder's Query / Clarification	MNGL' Reply
	<b>Commercial:</b>	
1	<b>Extension of Bid Due Date</b>	<b>Bid due date is extended upto 20.09.2017, 15:00 hours.</b>
	<b>Technical</b>	
1.	Please specify the width of the restoration	Width of the restoration is 800 mm.
2.	In item no 1: bituminous road point no. ii and iii please specify the layer name and thickness	Please see the attached drawing for typical Cross Section of Restoration of Trenches for Bituminous Road (Including Tack Coat on Top of BM & DBM)
3.	In item no 2: Concrete please specifies the thickness of all layer and layers name.	Please see the attached drawing for typical cross section of restoration of trenches for concrete surface.
4.	In item no 3: Paver block and tiles please specify the thickness and layer name.	Please see the attached drawing for typical cross section of restoration of trenches for cement concrete tiles / precast cc tiles / kota stone floor / red stone floor / paver blocks

Please submit the signed & stamped copy of Replies to Queries of the Bidders along with tender document with your techno-commercial offer as a token of acceptance.


All the others terms and conditions of the bid documents are unchanged.

With regards.

Ganesh Said  
Sr. Manager (C&P)



TYPICAL CROSS SECTION OF RESTORATION OF TRENCHES FOR BITUMINOUS ROAD ( INCLUDING TACK COAT ON TOP OF BM AND DBM




0.120

0.250

P.C.C.(1:2:4) TOP SURFACE

Granuler sub base (GSB) CLOSE GRADE II

TYPICAL CROSS SECTION OF RESTORATION OF TRENCHES FOR CONCRETE SURFACE



TYPICAL CROSS SECTION OF RESTORATION OF  
TRENCHES FORCEMENT CEMENT CONCRETE  
TILES/PRECAST CC TILES /KOTA STONE FLOOR /RED  
STONE FLOOR /PAVER BLOCKS