

 MAHARASHTRA NATURAL GAS LIMITED	Reply to bidder's queries against tender for procurement of pressure & differential pressure gauges for MNGL, Pune Bid No: MNGL/C&P/2016-17/118
---	--

Date: 23.03.2017

Replies to Queries of the Bidders

SUB: Replies to queries of the bidders' for procurement of pressure & differential pressure gauges for MNGL, Pune

REF: Bid Document No. MNGL/C&P/2016-17/118 dated 18.03.2017

Dear Sir,

Following are the replies to queries of the bidders'. Kindly note the same.

Sr. No.	Bidder's Query / Clarification	MNGL's Reply
1	Sensing Element Type - Piston / Diaphragm	Diaphragm
2	Sensing Element Material - SS / Elastomer	SS
3	Type - Gauge / Gauge + Switch	Gauge
4	Body Material	SS 316
5	Dial Size - 2.0" / 4.0" / 6.0"	4"
6	Connection	1/2" BSP
7	Porting - Inline / Bottom / Rear	Bottom
8	Case - SS 304 Std. / SS 304 Flange	SS304 Std.
9	Window - Glass / Acrylic / Toughened Glass / Safety Glass	Toughened glass
10	Seals-Buna (Std.) / EPDM / Viton	Buna
11	Switch	Not required
12	Mountings - Horizontal Pipe / Surface Mounting Bracket / 2" Vertical Pipe Mounting	Direct mounting
13	Maximum Working Pressure	19-20 Bar
14	Maximum Working Temperature	60 °C

Please submit the signed & stamped copy of Replies to Queries of the Bidders along with tender document with your techno-commercial offer as a token of acceptance.

All the others terms and conditions of the bid documents are unchanged.

With regards,

Shekhar D. Kankrej
Dy. Manager (C&P)