 <b>MAHARASHTRA NATURAL GAS LIMITED</b>	<b>REPLY TO BIDDERS QUERIES AGAINST TENDER FOR ANNUAL RATE CONTRACT FOR PROCUREMENT OF CNG CAR &amp; BUS DISPENSERS FOR CNG &amp; CGD NETWORK OF MNGGL, PUNE</b>  <b>Bid No.: MNGGL/C&amp;P/2017-18/60</b>
---	--

Date: 08.09.2017

**Replies to Queries of the Bidders**


**SUB: Replies to queries of the bidders for Tender for Annual rate contract for procurement of CNG Car & Bus Dispensers for CNG & CGD Network of MNGGL, Pune**

REF: Bid Document No. MNGGL/C&P/2017-18/60 dated 28.08.2017.

Dear Sir,

Following are the replies to queries of the bidders. Kindly note the same.

Sl. No.	Bidder's Query / Clarification	MNGGL' Reply
1	Clause no. 15, Page 20 of 62, Vendor List, Micro Motion (CNG 50 with 2700 transmitter), E & H Proline Promoss83 F Coriolis Flow meter  -We request you to include the below model of E&H flow meter which is being currently used in all CGD Dispenser for Car & Bus Dispensers : CNGMASS DCI 8DF08	E&H CNG Mass DCI Model is accepted.
2	Clause no. 15, Page 21 of 62, Vendor List, Fuelling Nozzle: NGV/NZS, OPW5000 series / Sherex, WEH, COMPAC  - We request you to include parker as a vendor for Nozzles.	Bidder to refer "Notes" in clause no 15, Vender List, page no.21 of 62.
3	Clause no 7.1.34, page 31 of 62, Vendor should include supply of breakaway coupling in each fill & vent hose suitable for NGV Industry.  - We request you to include parker as a vendor for Breakaway Couplings (Snaptite)	Accepted
4	Clause no 1.11, page 18 of 62, Location of ESD Button on Side Panel  -Compac dispenser ESD button is located on the side panel, which is easy to reach and adds to the aesthetic look of dispenser. Request to confirm the same.	Tender Condition Prevails.
5	Clause no. 15, Page 20 of 62, Vendor List, - Inclusion of Compac KG 80 mass flow meter in the approved list of products- Compac KG80 meter fulfills all the required conditions for MFM in the tender. It is in use in all CGD companies in India and has been running successfully for past 10 years and is approved by W&M for use in CNG application. Request you to include the same in vendor list.	Tender Condition Prevails.

 <b>MAHARASHTRA NATURAL GAS LIMITED</b>	<b>REPLY TO BIDDERS QUERIES AGAINST TENDER FOR ANNUAL RATE CONTRACT FOR PROCUREMENT OF CNG CAR &amp; BUS DISPENSERS FOR CNG &amp; CGD NETWORK OF MNGL, PUNE</b>  <b>Bid No.: MNGL/C&amp;P/2017-18/60</b>
---	--

Sl. No.	Bidder's Query / Clarification	MNGL' Reply
6	Clause no. 15, Page 20 of 62, Vendor List,  -Inclusion of Compac make Regulator valve in the approved list of products. -Compac make regulator valve is a part of our standard design. Request to include the same.  -Inclusion of Compac make safety valve in the approved list of products- Compac make safety valve is a part of our standard design. Request to include the same.	Accepted
7	Clause no. 7.1.33 (v), Page 31 of 62, Compac made High body dispenser (Legend Model) Which does not require high Masts. -MNGL has asked for Hi-masts to be provided with dispenser. Compac high body dispensers are operationally easier to maintain than low body dispensers which require Hi-masts. Request to consider the same.	Offered Dispenser Model should meet/ fulfill the tender specification.

Please submit the signed & stamped copy of Replies to Queries of the Bidders along with tender document with your techno-commercial offer as a token of acceptance.

All the others terms and conditions of the bid documents are unchanged.

With regards.

Ganesh Said  
Sr. Manager (C&P)