

 MAHARASHTRA NATURAL GAS LIMITED	REPLY TO BIDDERS QUERIES AGAINST TENDER FOR RC FOR THE PERIOD OF 2 YEARS FOR PROCUREMENT OF ISOLATION & APPLIANCE BALL VALVES FOR CGD NETWORK OF MNGL, PUNE Bid No.: MNGL/C&P/2017-18/37
---	---

Date: 04.08.2017

Replies to Queries of the Bidders

SUB: Replies to queries of the bidders against Tender for Rate Contract for the period of 2 years for Procurement of Isolation & Appliance Ball Valves for CGD Network of MNGL, Pune

REF: Bid Document No. MNGL/C&P/2017-18/37 dated 15.07.2017

Dear Sir,

Following are the replies to queries of the bidders. Kindly note the same.

Sl. No.	Bidder's Query / Clarification	MNGL' Reply
1	<p>Please note we have gone thru technical spec of ball valves 1/2" NPT and appliance ball valve 1/4" and we have observed that you have changed length of brass valves 1/2" to 57mm where as we had supplied in previous lot of 53mm length.</p> <p>Secondly we had supplied appliance ball valves 59.5 mm 1/4" in previous supply and both these valves are EN331 approved.</p> <p>We cannot understand what is the reason of change in length. Kindly get it amended ASAP.</p>	<p>Following are the modifications:</p> <p>Length for 1/2" Isolation Ball Valve : 56 ± 1 mm Length for 1/4" Appliance Ball Valve : 60 ± 1 mm</p> <p>For all other sizes tender condition prevails.</p>
2	Extension of Bid Due Date	Bid due date is extended upto 14.08.2017, 15:00 hours.

Please submit the signed & stamped copy of Replies to Queries of the Bidders along with tender document with your techno-commercial offer as a token of acceptance.

All the others terms and conditions of the bid documents are unchanged.

With regards.

Ganesh Said
Sr. Manager (C&P)